



7015 Macleod Trail-S.W.  
Suite 800  
Calgary, AB  
T2H 2K8  
Tel. (403) 296-1300  
Fax. (403) 296-6450  
[www.cgi.com/insurance.html](http://www.cgi.com/insurance.html)

September 12, 2006

Alberni-Clayoquot Regional District  
Sproat Lake Volunteer Fire Department

Subject: **Superior Tanker Shuttle Accreditation**

The Fire Underwriters' Survey is pleased to grant the Sproat Lake District of Alberni-Clayoquot with **Superior Tanker Shuttle Accreditation**. The test procedure was carried out on September 9, 2006 with the undersigned present. The flow rate during the 2-hour test period averaged 1,090 litres per minute or 240 imperial gallons per minute.

The membership of the Sproat Lake Volunteer Fire Department worked well as a team to achieve this accreditation. This accreditation will provide the citizens within the response district of the Sproat Lake Fire Suppression area with a dwelling protection grade of 3A.

Regards,

A handwritten signature in cursive script that reads 'C. Payne'.

Cindy A. Payne  
Fire Protection Specialist  
CGI Fire Underwriters Survey